



Control panel	VP	1-4	24V LNB LNA GND
Modbus RTU	A, B	1-2	RS485
Water mixing valve actuator	TG1	3-4	24V 24V
External DX unit	DX	5-6	24V GND
24V DC; 0-10V output	AUX	7-8	24V GND 24V
Supply air temp. sensor	B1	9-10	24V GND
Return water temp. sensor	B5	11-12	24V GND
Common Heating Cooling Alarm	OUTPUTS	13-14	NO NO NO
Water pump Max. load 100W	ST	15-16	230V N
Override	INPUTS	17-18	NO NO NO
Kitchen hood	C	19	NO
Fireplace		20	NO
Fire alarm		21	NC
Common		22	C
Supply air VAV sensor	B6	23-24	24V GND
Exhaust air VAV sensor	B7	25-26	24V GND
Air quality or humidity sensor 1	B8	27-28	24V GND
Air quality or humidity sensor 2	B9	29-30	24V GND
Air damper actuator Max. load 15W	FG1	31-32	230V N